



**NOTES:**

- 1.) ALL MATERIALS, BEDDING AND BACKFILL ARE PER BCWA SPECIFICATIONS AND SHALL BE INSPECTED AND APPROVED BY THE BCWA PRIOR TO BEING BACKFILLED AND/OR ACTIVATED.
- 2.) MAXIMUM TRENCH WIDTH FOR PAYMENT = 60" (INCHES).
- 3.) ROADWAY RESTORATION IN ACCORDANCE WITH ALL MUNICIPAL OR RIDOT PERMIT REQUIREMENTS.
- 4.) WHENEVER THERE IS A DISCREPANCY BETWEEN THIS DETAIL AND THE WRITTEN SPECIFICATIONS, THE SPECIFICATIONS SHALL GOVERN.

26.0 TRENCHDT-2015.DWG

**BCWA**

BRISTOL COUNTY WATER AUTHORITY

TRENCH DETAIL

NOT TO SCALE

450 CHILD STREET  
WARREN, RHODE ISLAND

DATE: 2/2015

DETAIL  
26.0